

SUMMARY REPORT

Applicant : INCONTROL TECH SDN. BHD.
 No.15, Jalan BRP 9/1D,
 Perusahaan Bukit Rahman Putra,
 47000 Sungai Boluh,
 Selangor Darul Ehsan, Malaysia.

Product : Product : REMOTE TERMINAL UNIT (RTU)
 Brand : iTEC 325
 Model : UCN - 2610A/122B0130
 UCL - 16DIO.P1

The INCONTROL TECH's RTU (Brand : iTEC325) has been tested according to the following standards for EMC requirements.


MEASUREMENT ITEM	Severity level	Result
Emissions Test :		
Radiated emission : CISPR 22 : 2005	CISPR 22 Class A	Pass
Immunity Test :		
IEC 61000-4-2 : 2001	Class IV	Criteria A
IEC 61000-4-3 : 2006	Class III	Criteria A
IEC 61000-4-4 : 2006	Class III	Criteria A
IEC 61000-4-5 : 2005	Class IV	Criteria A
IEC 61000-4-6 : 2006	Class III	Criteria A
IEC 61000-4-8 : 2001	Class IV	Criteria A
IEC 61000-4-12 : 2006	Class III	Criteria A
IEC 61000-4-16 : 2002	Class IV	Criteria A
IEC 61000-4-29 : 2000	Class IV	Criteria A
IEC 60255-5 : 2000	Dielectric - 2.5 kV	Criteria A
	Impulse - 5.0 kV	Criteria A

Prepared by

(Signature)
 MAHSOL MAHYUDDIN
 Technical Executive
 EMC Testing Section
 Tel : 03-55446153
 Email : mahsol@sirim.my
 Date : 23rd October 2007

SIRIM QAS INTERNATIONAL SDN. BHD.
 (Company No. 410334-X)

Building 4, SIRIM Complex
 1, Persiaran Dato' Menteri
 Section 2, P.O. Box 7035
 40911 Shah Alam
 Selangor Darul Ehsan
 MALAYSIA.



ISO/IEC 17025
 SAMM 085
 SAMM 086
 SAMM 087
 SAMM 219
 SAMM 231
 SAMM 299

074-A 074-C

Tel : 60-3-5544 6400
 Fax : 60-3-5510 9439
<http://www.sirim-qas.com.my>